

METROPOLITAN PIER AND EXPOSITION AUTHORITY



McCORMICK
GRADE • FLOOR • REPAIR

INVITATION FOR BIDS #2023-27-M
MPEA LOT A & HYATT PARKING STRUCTURE MAINTENANCE REPAIRS

ADDENDUM NO. (2)

August 3, 2023

This Addendum No. 1 consists of one (1) page and has the following information to be incorporated into the Invitation for Bid (IFB). Bidders must acknowledge receipt of this Addendum No. 1 in their IFB submittal in Required Form A, Bid Form.

Item #1: Bidders' questions and/or requests and the MPEA's responses are provided below.

Item #2: See revised Specifications:

- section 07 95 00: added 2.4 specification for Elastomeric concrete edged, extruded rubber expansion joint system
- deleted section 00 43 10

Item #3: Revised Bid Form in Excel format

	Bidders' Question:	MPEA's Response:
1	Please provide additional information for the floor drain grate cover replacements. Is there a product data sheet that can be provided for pricing?	The drain grates should be ductile cast iron capable of supporting 4,999 pound point loads (medium duty per ASME A112.6.3). Contractors should field verify the dimensions prior to purchasing but can be approximately 8-12 inches in diameter. Acceptable drain covers are listed below as a basis for design, and equivalent alternates may be submitted to the Engineer for approval. <ul style="list-style-type: none"> a. Wade 1200 and Smith 2140-M (12" diameter) b. Wade 1310 and Smith 2110-M (8½" diameter)